

The Employer 	The Engineer 	Supervision Consultant 	The Contractor 	MEP Project Manager	Sub-Contractor 
---	---	---	--	---------------------	---

Waldorf – Astoria 4B+G+M+43 Hotel Tower – Plot # 61070167 & 61070168 at West Bay, Doha, Qatar

## MATERIAL APPROVAL SUBMITTAL

Date: **09-Dec-2017** Reference: **C010-MT-06-0045** Rev. **00**

Material Description: **DIGITAL TEMPERATURE CONTROL VALVE**

Model Number, Brand Or Code Of Proposed Material:  
**ARMSTRONG**

Refer to the Attached Summary of Proposed Materials

Location Of Use: **Basment-04, Level-08 & Level-28.**



Attachments:  Catalog  Samples  Test Certificate  Other

Specification Section: **No Specs Available (Proposed Models are as Specified)**

Dwg ref?

Manufacturer Details	Supplier Details
Name : ARMSTRONG International SA. Country of Origin : Belgium. Address : Agent Telephone :	Name : Innovation Gate Trading Country : Doha, Qatar. Address : P.O.Box Agent Telephone : +974 4414 1964 / Fax : +974

1. Compliance statement should be included in the submittal.
2. Copy of the Contract Specification Section should be included in the submittal
3. All sheets must be signed & sealed by the Contractor and the Specialist Subcontractor(s)
4. Submittal reference number should be noted on the attachments

MEP Project Manager Representative Signature	The Contractor Representative Signature
<b>Mohammed Majeed</b>  Name Signature <b>09-Dec-2017</b> Date	<b>Juan Ballester Castro</b>  Name Signature  Date



**THE ENGINEER COMMENTS:**

Refer to comments on the attached sheet.



**ACTION: (As Marked)**

Approved    
 Approved as Noted    
 Revise & Resubmit    
 Not Approved

Reviewed By: 	For The Engineer: 	For The Employer:
---	--	-------------------

**3B+G+M+43 HOTEL & RESIDENTIAL APARTMENT BUILDING AT AL QASSAR/  
AL DAFNA – QATAR**



**Submittal Description** : Digital Temperature Control Valves  
**Manufacturer** : Armstrong  
**Reference No.** : C010-MT-06-0045  
**Contractor** : HARINSA QATAR.  
**Comments Date** : December 23, 2017

**Action: Approved as Noted**

**ENGINEER'S comments:**

1. Armstrong is approved as a brand name .
2. Contractor shall coordinate with all other trades and include the system description and sequence to the related drawings and operation and maintenance manual
3. Subject to system performance and final handing over
4. Country of origin, up to date test certificate need to be provided along with material delivery to site
5. Warranty shall be as per the project specified condition, from the date of HO, the same to be provided in the operation and maintenance submittal

1 | 1

<p><b>Sr. Mechanical Engineer</b></p> <p><b>Moataz Elzanaty</b></p> 	<p><b>Sr. Project Manager</b></p> <p><b>Omar Mohammad</b></p> 
---	--