


To: M. BASMAR
For Filing

AL KAMAL

ARCHITECTS
ENGINEERS
DOHA - QATAR
TEL: 43281 811 43281 8222 2012

18 07 18

SUBMITTAL	SUBMITTAL TRADE	SUBMITTAL PACKAGE	SUBMITTAL REFERENCE	Revision	SUBMITTAL DATE
	MAT	MECHANICAL- HVAC	KDO-MAT-MECH-014	00	13-JUNE-2018
CONTRACT TITLE:		KDO PRIVATE RESIDENCE		INNOVATION GATE TRADING CO. CONT. REF:	
FROM (Contractor):		AL KAMAL INTERNATIONAL GROUP			
TO (Supervision Consultant):		M/S: DIWAN AL EMARA			
Sub-Contractor:		AL EMADI GROUP			



18 JUL 2018

SUBMITTAL TYPE			QUANTITY
<input type="checkbox"/> Shop Drawings	<input type="checkbox"/> Samples	<input type="checkbox"/> Certificates	1 Original & 1 Copy & 1 CD
<input type="checkbox"/> Coordination Drawings	<input type="checkbox"/> Informational Submittal	<input type="checkbox"/> Manufacturer's Instructions..	
<input checked="" type="checkbox"/> Material Submittal	<input type="checkbox"/> Design Drawings	<input type="checkbox"/> Manufacturer's Field Reports	
<input type="checkbox"/> Method Statement	<input type="checkbox"/> Test Reports	<input type="checkbox"/> Other	
RECEIVED Sign ...			

ITEM DESCRIPTION	REMARKS
Material Submittal for Air Outlet (CIC BRAND-JORDAN)	YOUSEF M. AL VILLA 13 JUN 2018

Review and Approval Resubmitted for Review and Approval For Information

Contractor's Signature: *[Signature]* Date: *[Blank]*

CONSULTANT TO ENTER ACTION CODE AND REMARKS AND RETURN TO CONTRACTOR:

APPROVED APPROVED AS NOTED REVISE AND RESUBMIT REJECTED RETURNED-NOT REQUIRED

Comments:

- * Contractor to provide a valid reason for proposing new make CIC for air outlets instead of previous approved make ANDLOKLM.
- * Linear slot Diffuser model: CILS-AD1" 2 slot air flow does not match with air outlet schedule.
- * NO performance data available for Model: CILR-AD1"
- * All return linear slot diffuser should be with deflection blades.
- * Selected Model for linear Bar Grille are: supply - CI-SBR-DD & return - CI-RBG-SD with zero degree.
- * Selected Model for square diffuser is AIR Air SD-84
- * Selected Model for Grilles & Register is CI-Air SR-HD, CI-Air-SG-HD.
- * All the air outlets should be Anodized Aluminium Finish
- * Provide sample for each type of air outlet to be used on this project for client review & approval.

Consultant's Signature: *[Signature]* KDO PROJECT OFFICE DATE: 18/7/18

Provide test certificates for SD-84 6" x 6" Square diffuser CILS-AD1" and for linear bar grilles & registers.



received by: Engr Chris

14/06/2018