

Project :	Execution of Architectural Finishing, Partitions, Interior Decoration, Electrical & Mechanical Works	Ref No. :	HTCO-AR-MT-AC-003	
Contract No. :	2018/25	Date:	01-May-18	Revision: 1
Contractor :	ARAB UNITED CONSTRUCTION W.L.L. (arcon)	FROM :	ARAB UNITED CONSTRUCTION W.L.L. (arcon)	
		TO :	HANY TAWFIK CONSULTING OFFICE	

Attachments :	Discipline :	Approval Required By Date :
<input type="checkbox"/> Samples <input type="checkbox"/> Original Brochures <input type="checkbox"/> Specification Comparison Sheet <input checked="" type="checkbox"/> Technical Data	<input type="checkbox"/> Civil <input type="checkbox"/> Architectural <input checked="" type="checkbox"/> Mechanical <input type="checkbox"/> Electrical <input type="checkbox"/> Other (state)	

Attach all relevant literature marked by "clouding": to identify relevant description, current test certificates, samples as appropriate.

Material Description :	GRILLS & DIFFUSERS
Location / Area :	Ground Floor, 4th to 24th Floor
Drawing Ref. :	SD-HVAC-01 TO SD-HVAC-24
Specification Ref. :	

Manufacturer / Supplier :	
Company Name :	CIC
Country of Origin :	JORDAN
Local Agent :	MEP INTERPRISES

Delivery :	
Production Period :	2 WEEKS
Total Delivery Time :	4-5 WEEKS
Expected Date of Delivery on Site :	
Time Required at Site:	

For Arab United Construction (arcon):		
NAME : ENGR. MAYSARA ABDUL MAJID	SIGNATURE : 	DATE : 1-May-2018

HTCO Comment :

- * Quantity and store for materials under contractor responsibility
- * Finishing color and style to be approved with arch engineer and client
- * Selection to be done under contractor and reflected on shop drawings
- * All units to provide with OBD to balance air FAS

A - APPROVED
 B - APPROVED WITH COMMENTS
 REVISE & RESUBMIT
 REJECTED

NAME :	SIGNATURE :	DATE :

* Factory visit required to check custom dimension and finishing

DISTRIBUTION :

Original :	<input type="checkbox"/> ARCON
Copies :	<input type="checkbox"/> SJC <input type="checkbox"/> HTCO

* All FAS to be install with screw not wall install
 * Contractor to follow re-completion of installation

9-5-2018