

MATERIAL SUBMITTAL

Project:	Al Seeliya Tower	Project No.	158001
Client:	Al Sawari Real Estate (Sheikh Faisal Al Thani)	Contractor:	GETTCO Construction
Consultant:	Meinhardt Consulting Engineering	Reference No.	GETC/PN#01/M/DS/MS/520
		Rev No.	00
		Date:	06/11/2017

Discipline: Civil Architectural Electrical Mechanical Others (specify)

Submittal Type :

<input type="checkbox"/> Drawing	<input type="checkbox"/> Test Result / Certificates	<input type="checkbox"/> Program & schedule	<input checked="" type="checkbox"/> Sample
<input type="checkbox"/> Design calculation	<input type="checkbox"/> Reports	<input type="checkbox"/> Forms/ checklist	
<input type="checkbox"/> Data sheet	<input type="checkbox"/> Pre-Qualification	<input type="checkbox"/> Quality Plan	
<input checked="" type="checkbox"/> Material	<input type="checkbox"/> Sketch	<input type="checkbox"/> Organization Chart	

Description of Submittal: (Note: Material Submittals – the brand names, item codes, manufacturer & supplier with Country of Origin must be included)

Mechanical Material Submittal Ref: GETC/PN#01/M/DS/MS/520, Grills & Diffusers, 1)Supply Air Diffusers : CI Air SD – S4, 2)Linear Slot Diffusers : CILS –AD3/4" 3) Linear Bar Grill : CI-SBR DD & CI-RBG-SD, Supplier: Innovation Gate Trading Co. Manufacture: Cooling Industries Co. CIC-Jordan

MEINHARDT (SINGAPORE) PTE, LTD.
QATAR BRANCH
PROJECT: SEELIYA TOWER
06 NOV 2017
RECEIVED 3:30

*1 no. of Original & 1 nos of Copies
*1 Soft Copy (CD)

Gettco CONSTRUCTION Project Management
Incoming No. ()
Date: 08/11/17 02:30

Prepared & Checked By: (Contractor / Sub-Contractor)				Project Manager:			
Name:	Mr. Wasim Raja/BES	Name:	Mr. Mohamad Karroum / BES	Name:	Mr. Ahmed Mustafa/ Gettco	Name:	Mr. Ihab Jalal/ Gettco
Designation:	Mech. Engineer	Designation:	Project Manager	Designation:	Mechanical Head	Designation:	Project Manager
Signature:	[Signature]	Signature:	[Signature]	Signature:	[Signature]	Signature:	[Signature]
Date:	06 Nov-2017	Date:	06-Nov-2017	Date:	06/11/2017	Date:	06/11/17

(CONSULTANT) - MEINHARDT'S COMMENTS

- * Material is approved subject to the following conditions:-
- 1) Submit list for all air outlets for each floor for each PCU show in all technical data for consultant review and approval.
 - 2) Air outlet colors shall be matches with walls / ceiling and approved by Architectural engineer, color shall be matt not shiny.
 - 3) opposed blades damper shall be screw type not handle type adjusted.
 - 4) rubber gasket shall be fixed around the air outlet frame.

A - APPROVED B - APPROVED WITH COMMENTS C - REVISE & RESUBMIT D - REJECTED

Comments Attached N - NOTED

Reviewed By:	Approved By: (Project. Manager)
Name:	Name:
Signature:	Signature:
Date:	Date:

Gettco CONSTRUCTION Project Management
Date: 06/11/17
Issue No. 0