

PROJECT:	QESC-New Camp Project- Design & Build	PROJECT REF:	Q-102-01
CONTRACTOR:	Bahadir Construction Engineering Contracting and Trading Inc. Co.	CLIENT:	QATAR ARMED FORCES (QAF) / QECE- WING -2
SUBCONTRACTOR:	The BEST	CONSULTANT:	Engineering Adnan Saffarini (EAS)
SUBMITTAL REF:	SSC-BAH-0001-DSS-MEP-0962	NEW SUBMISSION <input checked="" type="checkbox"/>	RE-SUBMISSION <input type="checkbox"/>

IF RE-SUBMITTAL – PLEASE REFER TO PREVIOUS SUBMITTAL REFERENCE:

PURPOSE OF ISSUE:	APPROVAL <input type="checkbox"/>	INFORMATION <input checked="" type="checkbox"/>	CONSTRUCTION <input type="checkbox"/>	RECORD <input type="checkbox"/>	OTHER <input type="checkbox"/>
DOCUMENT TYPE:	CLEINT REVIEW			DISCIPLINE:	
SUBMITTAL DATE:	06 October 2020	RESPONSE DUE:	HARD COPIES <input type="checkbox"/>		E-FILES <input checked="" type="checkbox"/>

ITEM No.	DOCUMENT TITLE	DOCUMENT NUMBER	REV.	REVIEW STATUS
1	SSC-BST-1008-MAR-AC-00620 R0 SSC Client Review - Material Approval Request from M/s Maven Trading & Installation WLL Manufacturer by Japan Air Filter Malaysia Sdn Bhd (JAF) for Carbon Filter for Kitchen AHU in Building 1008	QECE/FAX/SPDD/Q-102-01/20/6396 SSC-BST-1008-MAR-AC-00620 R0	0	B
2	SSC-BST-1014-MAR-AC-00611 R0 SSC Client Review - Material Approval - Motorized Valves & Accessories for Chiller Yard 2041, 2071 & 2081	QECE/FAX/SPDD/Q-102-01/20/6401 SSC-BST-1014-MAR-AC-00611 R0	0	B
-	*** Nothing Follows ***	-	-	

Document Review Status Legend: A = Approved, B = Approved as Noted, C = Revise & Re-Submit and E = Not Approved / Rejected

Reviewers Comments (applicable to status B, C and E)

SUBMITTED BY	REVIEWED BY	APPROVED BY
Name: Kaushal Paliwal	Name: Tarun Behal	Name: Tevfik Ahmet Sarioglu
Position: QA/QC Manager	Position: MEP Manager	Position: Project Manager
Organisation: Bahadir	Organisation: Bahadir	Organisation: Bahadir
Signature: 	Signature: 	Signature: 
Date: 06 October 2020	Date: 06 October 2020	Date: 06 October 2020



Qatar Armed Forces
 Qatar Emiri Corps of Engineers
 P. O. Box : 5735 - 9575 Doha - Qatar
 Tel: 44612111 Fax: 44612811/44605300



القوات المسلحة القطرية
 سلاح المهندسين الاميري القطري
 ص.ب : ٥٧٣٥ - ٩٥٧٥ الدوحة - قطر
 هاتف : ٤٤٦١٢١١١ ، فاكس : ٤٤٦١٢٨١١ / ٤٤٦٠٥٣٠٠

FAX MESSAGE

Message No.	QECE/FAX/SPDD/Q-102-01/20/ 6401	Date	05 /10/2020
Fax To	M/s. BAHADIR INSAAT	Fax No.	4465 1663
Attention	The Manager	No. of Pages:	03

Project	Qatar Emiri Signal Corps New Camp [Design & Build] (Q-102-01) Material Approval
---------	--

Ref.: Your letter No. SSC-BAH-PM-QECE-LT-03153 dated 24/09/2020

With reference to the above mentioned subject, please find the status of the following drawings as mentioned below: -

#	Ref. #	Material	Remarks
1	SSC-BST-1014- MAR-AC-00611-R00	Motorized Valves & Accessories for Chiller Yard 2041, 2071 & 2081	Approved with comments

Refer to the attached request form for details.

For your information and further action.

Regards,



Maj. Gen. Eng. Ali Al-Hall
 Staff Director - QECE

BAHADIR CONSTRUCTION		
QESC-New Camp Project- Design & Build (Q-102-01)		
DISTRIBUTE	INFO	ACTION
PD		
CM		
DM		
Contracts		
PCM		
MEP		✓
PLANNING		
PROC		
COM		
QA/QC		✓
QS		
QHSE		
ADM/HR		
BO		
Other		B&S
Date		
By		

Please confirm receipt of this message. If the message is incomplete or illegible, please contact Tel: 44612714

CC: 1. PSSU + OE 2. SPDD	Transmitted
	On:
	By:

Mike, John



QATAR ARMED FORCES QATAR EMIRI CORPS OF ENGINEERS

Project:
Qatar Emiri Signal Corps New Camp Project-Design & Build (Q-102-01)

Camp:
Supervising Wing: 2

APPROVAL OF MATERIALS

Ref. No. SSC-BST-1014-MAR-AC-00611-R00

Submission No.

1st 2nd 3rd 4th

Architectural Civil Plumbing Mechanical Electrical Specify

Submitted as: Spec. Alternative (If Alternative state reasons on attachment with valid attachments)

Location : Signal Corps New Camp Project (For Chiller yards) **Spec. Ref. :** QCS 2014, Section 22, Part 9


Material : Motorized Valves & Accessories for Chiller Yard 2041, 2071 & 2081
 1. Butterfly Valve
 2. Butterfly Valve Actuators (ITQ)
 3. Modulating Kit 24V for ITQ **BOQ Ref. :** N/A

Manufacturer : HERZ **Data Sheet :** Included

Agent : Innovation Gate Trading (Approved PQ Ref No.- QECE-FAX-PSSU-W2-Q-102-01-19-708) **Country of Origin :** AUSTRIA

Sample : NA **Literature :** Material Proposal Sheet, Compliance Statement, Product Data, Previous Approvals, Catalogues, Certificates

Contractor's Signature & Stamp: Tevfik Ahmet Sarıoğlu
Project Manager



DATE: 24-Sep-20

Approved Approved with Comments Rejected

Comments:

* Refer to the attached form for comment

Sr. Engineer:

Date

Project Coordinator:

Date

Approved Approved with Comments Rejected

Commander - QECE

Date :

Note: This document is a controlled document, to be used only for this project. Circulation/publishing of the above copy is restricted and shall not be used without written consent from QAF. Contractor/supplier shall not use this document as a reference for other projects. In case of non-compliance, strict action will be initiate

**QATAR ARMED FORCES
QATAR EMIRI CORPS OF ENGINEERS
SPDD – Mechanical Department**

MATERIAL SUBMITTAL COMMENTS

Project:	Q-102-01	
Sub. Ref. No.	SSC-BST-1014-MAR-AC-00611-R00	
Material Description	Motorized Valves and Accessories for Chiller Yard 2041,2071 & 2081	
Manufacturer	HERZ	Country of Origin: Austria
Approval Status	Approved as Noted	

Mechanical Comments:-

- Size, type, flow etc. as per approved shop drawings and project requirements.
- Coordinate with electrical prior to order and installation.
- Material shall be compatible with the equipment to be used.
- Selection shall be coordinated with manufacturer/supplier prior to proceeding further.
- Installation shall be done as per manufacturers recommendations and approved method of statement also fully coordinate with all other services prior to order and installation.
- Guarantee / Warranty shall be 5 years from the date of project handover.
- Submit warranty, country of origin, test certificates and all other required valid documents upon delivery.
- Contractor shall be responsible to comply with relevant local authorities codes / regulations, QCS 2014 and project requirements.

Note:

1. Comply comments on the previous submittal (SSC-BST-0001-MAR-AC-00204-R01)

Reviewed by:

Mechanical Engr.



Checked by:

Head of Mechanical Dept.



Note: This document is a controlled document, to be used only for this project. Circulation/publishing of the above copy is restricted and shall not be used without written consent from QAF. Contractor/supplier shall not use this document as a reference for other projects. In case of non-compliance, strict action will be initiated