





CONTRACTOR'S MATERIAL SUBMITTALS FOR (FOX HILLS MUP10 & MUP11)

PROJECT TITLE: (2B+G+M+3) SHOP & RESI. FLAT FOX HILLS MU/P11 LUSAIL (2018/7128) & FOX HILLS MU/P10 LUSAIL (2018/7529)	OWNER: MRS. NAEMA SALEH G.A. AL KUWARI	
DATE: 6th February 2021	SUBMITTAL NO: 55	REV. 00
CONSULTANT: ALPHA CONSULTING	CONTRACTOR: SHARD PROJECTS COMPANY	
Location: FOX HILLS MUP10 & MUP11	DESCRIPTION: PICV HOOK VALVES FOR CHILLED WATER	
ENCLOSED: 1 SET HARD COPY & 1 CD SOFT COPY	MANUFACTURER: HERZ	
DATE REQUIRED AT SITE:	LOCAL AGENT: SIDRA FOR ENGINEERING SERVICES	
COPY TO BARJOUS ARCHITECTS: ENGINEER: AHMAD AWWAD	COUNTRY OF ORIGIN: AUSTRIA	
SUPPORTING INFORMATION: <ul style="list-style-type: none"> COMPANY PROFILES TECHNICAL DATA 	CONTRACTOR'S SIGNATURE & SEAL: 	
CONSULTANT'S COMMENTS: <u>PICV HOOK VALVES FOR CHILLED WATER WITH ACTUATOR & FLEXIBLE HOSE:</u> <u>VALVE: APPROVED AS NOTED:</u> <ol style="list-style-type: none"> 1. THE BRAND NAME FOR ALL HOOK-UP AND VALVES OF CHILLED WATER FROM "HERZ" IN AUSTRIA IS APPROVED. 2. THE SAMPLE FOR COMBINED VALVE ON FAN COIL FROM "HERZ" IN AUSTRIA IS ACCEPTABLE. 3. RE-CHECK ALL THE SIZES OF VALVES AS PER ENLARGED CAPACITIES WITH RATING PRESSURE "PN20". 4. SUBMIT RISER DIAGRAM CLARIFIED ALL THE SIZES OF FAN COIL UNITS AND VALVES SIZES THROUGH SCHEDULE. 5. PROVIDE ALL THE SIZES OF HOOK-UP ON CHILLED WATER PUMPS AND VALVES ON NEW SIZES FOR FAN COIL UNITS AS PER ENLARGED NEW CAPACITIES. 6. SUBMIT SEPARATE SUBMITTAL FOR EACH TYPE OF VALVE FOR APPROVAL AS PER NEW CAPACITIES. 		
<div style="display: flex; justify-content: space-between; align-items: center;"> <div style="text-align: center;"> APPROVED <input type="checkbox"/> </div> <div style="text-align: center;"> APPROVED WITH COMMENTS <input checked="" type="checkbox"/> </div> <div style="text-align: center;"> REVISE & RESUBMIT <input type="checkbox"/> </div> <div style="text-align: center;"> REJECTED <input type="checkbox"/> </div> </div>		
SIGNATURE:	DATE: 11th FEBRUARY 2021	



DOCUMENT TRANSMITTAL					
SES Ref. No.	TD-SES-31-021	Job No.	SES-1230	Date	4.02.2021
TO		Project	Proposed (2B+G+M+3) Shop and Residential Flat Building at Lusail for Naema Saleh G A Al Kuwari		
Fax	+974 44440636	Subject	MATERIAL SUBMITAL&SAMPLE		
Tel	+974 44440636	Attention	Technical Office		
Kindly find enclosed the following					
SR NO	Drawing/ Document No.	Description	Rev. No	Copy No	Attachments
1	MAR-SES-AC-027	PICV HOOK VALVES FOR CHILLED WATER WITH ACTUATOR & FLEXIBLE HOSE	0	3	hard copy + soft copy
2		SAMPLE			
 Initiator's Signature		Mechanical Engineer Designation		4.02.2021 Date	
Please acknowledge receipt of the item(s) listed above by signing and returning a copy of this form					
 Receiver's Signature		 Designation		 Date	
Remarks:					

MATERIAL APPROVAL SUBMITTAL

PROJECT: PROPOSED (2B+G+M+3) SHOP & RESI. FLAT BUILDING

CLIENT: NAEMA SALEH G A AL KUWARI

MAIN CONTRACTOR: SHARD

MEP CONTRACTOR: SIDRA FOR ENGINEERING SERVICES

MANUFACTURER



(HERZ - AUSTRIA)

LOCAL SUPPLIER



**Innovation Gate Trading &
Contracting Co W.L.L.I**

P.O. Box: 202278 Doha-Qatar,
Tel.: +974 44441137 Fax: +974 44441138