



MATERIAL SUBMITTAL	SUBMITTAL TRADE	SUBMITTAL PACKAGE	SUBMITTAL REFERENCE	REVIEW CYCLE	SUBMITTAL DATE
	MECH	HVAC	DTC-ACE-228-MAT-HVAC-0023	01	19 AUG. 2020
CONTRACT TITLE:	Al Meera Convenience Store at Jeryan Jenaihat Branch			CONTRACT REF:	
FROM (Contractor):	Derwind Trading & Contracting Co.				
TO (Supervision Consultant):	Arab Consulting Engineers (Moharram Bakhoum)				
<p align="center">SUBMITTAL TYPE</p> <input type="checkbox"/> Shop Drawings <input type="checkbox"/> Samples <input type="checkbox"/> Certificates <input type="checkbox"/> Coordination Drawings <input type="checkbox"/> Informational Submittal <input type="checkbox"/> Manufacturer's Instructions <input checked="" type="checkbox"/> Product Data <input type="checkbox"/> Design Data <input type="checkbox"/> Manufacturer's Field Reports <input type="checkbox"/> Construction Photographs <input type="checkbox"/> Test Reports <input checked="" type="checkbox"/> Other					<p align="center">QUANTITY</p> 3 copies with CD
ITEM DESCRIPTION			REMARKS		
Material Submittal for REFRIGERANT COPPER PIPES (with Sample)			Supplier: IGTC Brand: MUELLER Country of Origin: USA		
<input checked="" type="checkbox"/> Review and Approval <input type="checkbox"/> Resubmitted for Review and Approval <input type="checkbox"/> For Information					
CONTRACTOR QA/QC:		PROJECT MANAGER:		Mr. Mohamed Talkhan	
SUBCONTRACTOR QA/QC:		PROJECT MANAGER:		Engr. Korani Radwan Faisal	
COPIES TO:	<input type="checkbox"/>	<input type="checkbox"/> Consultant	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/> File
ENCLOSURES TO:	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
CONSULTANT TO ENTER ACTION CODE AND REMARKS AND RETURN TO CONTRACTOR:					
<input type="checkbox"/> General	<input type="checkbox"/> Architect	<input type="checkbox"/> Structure	<input type="checkbox"/> Mechanical	<input type="checkbox"/> Plumbing	<input type="checkbox"/> Electrical
<input type="checkbox"/> Landscape	<input type="checkbox"/> Others				
<input type="checkbox"/> Approved <input checked="" type="checkbox"/> Approved as Noted <input type="checkbox"/> Revise and Resubmit <input type="checkbox"/> Not Approved					
Remarks : ① Material sample planology is approved. ② Refer to Rev.(0) comments.					
Supervision Consultant's Signature: 					Date: 08/22/20
COPIES TO:	<input type="checkbox"/> PM Management	<input checked="" type="checkbox"/> Contractor	<input type="checkbox"/> Consultant	<input type="checkbox"/> Client	<input type="checkbox"/> File
ENCLOSURES TO:	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Note: Allow for at least fourteen working days for review.

Form: Submittal



H/4
 RECEIVED
 22 AUG 2020
 BY: 



MATERIAL SUBMITTAL	SUBMITTAL TRADE	SUBMITTAL PACKAGE	SUBMITTAL REFERENCE	REVIEW CYCLE	SUBMITTAL DATE
	MECH	HVAC	DTC-ACE-228-MAT-HVAC-0023	0	09 AUG. 2020
CONTRACT TITLE: Al Meera Convenience Store at Jeryan Jenaihat Branch			CONTRACT REF:		
FROM (Contractor): Derwind Trading & Contracting Co.					
TO (Supervision Consultant): Arab Consulting Engineers (Moharram Bakhoum)					
SUBMITTAL TYPE					QUANTITY
<input type="checkbox"/> Shop Drawings <input type="checkbox"/> Coordination Drawings <input checked="" type="checkbox"/> Product Data <input type="checkbox"/> Construction Photographs					3 copies with CD
<input type="checkbox"/> Samples <input type="checkbox"/> Informational Submittal <input type="checkbox"/> Design Data <input type="checkbox"/> Test Reports					
<input type="checkbox"/> Certificates <input type="checkbox"/> Manufacturer's Instructions <input type="checkbox"/> Manufacturer's Field Reports <input checked="" type="checkbox"/> Other					
ITEM DESCRIPTION			REMARKS		
Material Submittal for REFRIGERANT COPPER PIPES			Supplier: IGTC Brand: MUELLER Country of Origin: USA		
<input checked="" type="checkbox"/> Review and Approval <input type="checkbox"/> Resubmitted for Review and Approval <input type="checkbox"/> For Information					
CONTRACTOR QA/QC:		PROJECT MANAGER:		Mr. Mohamed Talkhan	
SUBCONTRACTOR QA/QC:		PROJECT MANAGER:		Engr. Korani Radwan Faisal	
COPIES TO:		<input type="checkbox"/> Consultant		<input type="checkbox"/> File	
ENCLOSURES TO:		<input type="checkbox"/>		<input type="checkbox"/>	
CONSULTANT TO ENTER ACTION CODE AND REMARKS AND RETURN TO CONTRACTOR:					
<input type="checkbox"/> General <input type="checkbox"/> Architect <input type="checkbox"/> Structure <input type="checkbox"/> Mechanical <input type="checkbox"/> Plumbing <input type="checkbox"/> Electrical <input type="checkbox"/> Landscape <input type="checkbox"/> Others					
<input type="checkbox"/> Approved <input checked="" type="checkbox"/> Approved as Noted <input type="checkbox"/> Revise and Resubmit <input type="checkbox"/> Not Approved					
Remarks :					
..... Approved as noted subject to: 1- The proposed manufacturer MUELLER - USA is accepted. 2- The pipes size selected shall be complying with AC units recommendations. 3- Country origin, and test certificates shall be providing along with material on site inspection. 4- All pipes, and their fittings shall be engraved with manufacturer brand. 5- Provide sample for final approval. 6- Contractor shall provide installation method statement for approval before installation starting.					
Supervision Consultant's Signature:				Date : 13/08/2020	
COPIES TO:		<input type="checkbox"/> PM Management		<input type="checkbox"/> Client	
ENCLOSURES TO:		<input type="checkbox"/>		<input type="checkbox"/>	

Note: Allow for at least fourteen working days for review.

Form: Submittal



MATERIAL SUBMITTAL FOR: REFRIGERANT COPPER PIPES (with Sample)

SUBMITTAL REF. No. : DTC-ACE-228-MAT-HVAC-0023 REV 01

COMPLIANCE STATEMENT

S/N	COMMENTS	REPLY
1	The proposed manufacturer MUELLER - USA is accepted.	noted
2	The pipes size selected shall be complying with AC units recommendations.	noted
3	Country origin, and test certificates shall be providing along with material on site inspection.	noted
4	All pipes, and their fittings shall be engraved with manufacturer brand.	noted
5	Provide sample for final approval.	comply , refer to the sample board
6	Contractor shall provide installation method statement for approval before installation starting.	noted

THE BEST

شركة الأفضل للتجارة والمقاولات ذ.م.م
The Best Trading & Contracting Co. w.l.l.

PROJECT : AL MEERA CONVENIENCE STORE SCHEME AT JERYAN JENAIHAT
SAMPLE FOR : REFRIGERANT COPPER PIPES (with Sample)
BRAND : MUELLER
C.O.O. : USA
SUPPLIER: IGTC
REF. NO.: DTC-ACE-228-MAT-HVAC-0023 REV 01

