



MINISTRY OF FOREIGN AFFAIRS
GOVERNMENT OF PAKISTAN



NATIONAL ENGINEERING SERVICES PAKISTAN LIMITED



Engineering & Construction

Project Name:
Project Number:

PAKISTAN EMBASSY COMPLEX DOHA - QATAR
3450

MATERIAL APPROVAL REQUEST (MAR)

Submittal Contents: - Material/Sample - Mock-up - Catalogue/Brochure - others _____
MAR No. : MS-PEC/3450-EL-012 Rev. 2
Date Submitted : 24-Apr-2018

Trade / Discipline:

- Civil - Architectural - Electrical - Information Tech. (IT)
 - Structural - Mechanical - Plumbing - Others _____
 - Landscape - Interior Design

Date Required on Site: _____
Production Period: 3 days
Total Delivery Time: 24 APR 2018
Expected Arrival on Site: 11:20Am

Description of Material / Equipment:

LIGHT FIXTURES

References:

a.) Specs. Ref. : _____ c.) QCS 2010 Ref. : _____
b.) Drawing Ref. : _____ d.) Statutory Req. : _____
c.) BOQ Ref. : _____ e.) Specified Vendors List : _____
Others : _____

Manufacturer / Supplier Details:

a.) Local Supplier / Agent:

Company Name : ADVANCED LIGHTING SOLUTIONS
Address / Contacts : P.O BOX-90535
Tel:44323965 Fax: -44814996

- Locally Manufactured

- Imported

Country of Origin: Turkey

b.) Manufacturer :

Company Name : IKIZLER LIGHTING
Address / Contacts : _____



Prepared by: (Contractors PE or CM)

[Signature]
Name / Sign / Date

Verified by: (Contractors QA/QC, QS, or Proj. Coordinator)

[Signature]
Name / Sign / Date

Recommended for Approval by: (Contractor's PM)

[Signature]
Name / Sign / Date

COMMENTS BY THE CONSULTANT

- ① All lamps should be cool day light.
- ② Submittal lux calculation & quantity should be according to lux level.
- ③ All fittings should be LED as submittal with out cost implication (No extra cost)
- ④ Installation should be under supervision of supplier.
- ⑤ Spare fitting should be provided as per DCS along with main supply
- ⑥ chandelier will be processed separately.

(Use a separate comments sheet when necessary, for easy traceability purposes do not forget to include the MAR No., Revision No., & corresponding date of this MAR to the comments sheet.)

Submittal Status :

- A - Approved - B - Approved as Noted - C - Revise and Resubmit - D - Rejected

Supervision Consultant Signature :

[Signature]
Name & Signature
MEP
Designation
29/05/2018
Date

[Signature]
Name & Signature
RE/PM
Designation
29/5/2018
Date

Client Approval / Endorsement (when required) :

Name & Signature

Designation

Date

Approval or comments to the submittals does not relieve the Contractor from their responsibilities. The assessment is to review the general conformance and compliance of the submittal to the contract and specification requirements.